Instruction Sheet
P/N 1125091_03
- English -

Profinet IO Network Interface Card Disclosure

Description

This Profinet IO communication card requires a new GSDML file to provide instant integration with the PROFINET communication protocol. New firmware versions of the Profinet IO communication card are not backwards compatible with older GSDML files. For this reason, Nordson will provide a GSDML file for both old and new firmware versions of the Profinet IO communication card.

NOTE: The Profinet IO communication card with firmware version 5.07 or older cannot be used with the same GSDML file as Profinet IO communication cards with firmware version 5.09 or newer. Additionally, It is not possible to replace a Profinet IO communication card of firmware version 5.07 or older with one of firmware version 5.09 or newer. You must update the GSDML file before replacing the Profinet IO communication card.

Figure 1 Profinet IO card with firmware version 5.09

Obtain the Device Master File

Nordson Corporation provides a GSDML for the technical description of the Profinet IO card described in this manual. The GSDML file is included with the Siemens Profinet IO starter kit. The starter kit and GSDML files for Profinet IO cards with firmware versions 5.07 and 5.09 can be downloaded from:
http://emanuals.nordson.com/adhesives/software/plc_comm.asp

Additional configuration instructions can be found in our Profinet IO Network Interface Card Customer Product Manual that is available at the same link

Issued 04/2024
Copyright 2024. Nordson and the Nordson logo are registered trademarks of Nordson Corporation.